

# REDUCING TEE



## Cast Iron - Class 125 Fittings


### MATERIAL SPECIFICATIONS

Cast iron threaded fittings are UL & ULC Listed and FM Approved.


Cast iron per ASTM A126.

Dimensions conform to ANSI B16.4 Class 125.

Threads are NPT per ANSI/ASME B1.20.1.



For Listings/Approval Details and Limitations, visit our website at [www.anvilint.com](http://www.anvilint.com) or contact an Anvil® Sales Representative.



### REDUCING TEE

Nominal Size	Max. Working Pressure▲	Dimensions			Approx. Wt. Each
		A	B	C	
In. (mm)	PSI (kPa)	In. (mm)	In. (mm)	In. (mm)	Lbs. (kg)
1 x 1/2 x 1/2	300	1.50	1.36	1.50	1.08
25 x 15 x 25	2065	38.10	34.54	38.10	0.49
1 x 3/4 x 1/2	300	1.50	1.45	1.50	1.18
25 x 20 x 25	2065	38.10	36.83	38.10	0.54
1 x 1 x 1/2	300	1.26	1.26	1.36	0.95
25 x 25 x 15	2065	32.00	32.00	34.54	0.43
1 x 1 x 3/4	300	1.37	1.37	1.45	1.10
25 x 25 x 20	2065	34.79	34.79	36.83	0.50
1 1/4 x 1 x 1/2	300	1.34	1.26	1.53	1.17
32 x 25 x 15	2065	34.03	32.00	38.86	0.53
1 1/4 x 1 x 3/4	300	1.45	1.37	1.62	1.38
32 x 25 x 20	2065	36.83	34.79	41.14	0.63
1 1/4 x 1 x 1	300	1.58	1.50	1.57	1.47
32 x 25 x 25	2065	40.13	38.10	39.87	0.67
1 1/4 x 1 x 1 1/4	300	1.75	1.67	1.75	1.80
32 x 25 x 32	2065	44.45	42.41	44.45	0.82
1 1/4 x 1 1/4 x 1/2	300	1.34	1.34	1.53	1.37
32 x 32 x 15	2065	34.03	34.03	38.86	0.62
1 1/4 x 1 1/4 x 3/4	300	1.45	1.45	1.62	1.54
32 x 32 x 20	2065	36.83	36.83	41.14	0.70
1 1/4 x 1 1/4 x 1	300	1.58	1.58	1.67	1.65
32 x 32 x 25	2065	40.13	40.13	42.41	0.75
1 1/2 x 1 x 1/2	300	1.41	1.34	1.66	1.41
40 x 25 x 15	2065	35.81	34.03	42.16	0.64
1 1/2 x 1 x 3/4	300	1.52	1.37	1.75	1.65
40 x 25 x 20	2065	38.60	34.79	44.45	0.75
1 1/2 x 1 x 1	300	1.65	1.50	1.80	1.65
40 x 25 x 25	2065	41.91	38.10	45.72	0.75
1 1/2 x 1 x 1 1/4	300	1.82	1.67	1.88	2.00
40 x 25 x 32	2065	46.22	42.41	47.75	0.91
1 1/2 x 1 x 1 1/2	300	1.94	1.8	1.94	2.30
40 x 25 x 40	2065	49.27	45.72	49.27	1.04
1 1/2 x 1 1/4 x 1/2	300	1.41	1.34	1.66	1.58
40 x 32 x 15	2065	35.81	34.03	42.16	0.72
1 1/2 x 1 1/4 x 3/4	300	1.52	1.45	1.75	1.72
40 x 32 x 20	2065	38.60	36.83	44.45	0.78
1 1/2 x 1 1/4 x 1	300	1.65	1.58	1.80	1.85
40 x 32 x 25	2065	41.91	40.13	45.72	0.84
1 1/2 x 1 1/4 x 1 1/4	300	1.82	1.75	1.88	2.22

### REDUCING TEE

Nominal Size	Max. Working Pressure▲	Dimensions			Approx. Wt. Each
		A	B	C	
In. (mm)	PSI (kPa)	In. (mm)	In. (mm)	In. (mm)	Lbs. (kg)
1 1/2 x 1 1/4 x 1 1/2	300	1.94	1.88	1.94	2.45
40 x 32 x 15	2065	49.27	47.75	49.27	1.11
1 1/2 x 1 1/2 x 1/2	300	1.41	1.41	1.66	1.76
40 x 40 x 40	2065	35.81	35.81	42.16	0.80
1 1/2 x 1 1/2 x 3/4	300	1.52	1.52	1.75	1.87
40 x 40 x 20	2065	38.60	38.60	44.45	0.85
1 1/2 x 1 1/2 x 1	300	1.65	1.65	1.80	1.94
40 x 40 x 25	2065	41.91	41.91	45.72	0.88
1 1/2 x 1 1/2 x 1 1/4	300	1.82	1.82	1.88	2.29
40 x 40 x 32	2065	46.22	46.22	47.75	1.04
2 x 1 x 2	300	2.25	2.02	2.25	3.40
50 x 25 x 50	2065	57.15	51.30	57.15	1.54
2 x 1 1/4 x 2	300	2.25	2.10	2.25	2.80
50 x 32 x 50	2065	57.15	53.34	57.15	1.27
2 x 1 1/2 x 1/2	300	1.49	1.41	1.88	2.09
50 x 40 x 15	2065	37.84	35.81	47.75	0.95
2 x 1 1/2 x 3/4	300	1.60	1.52	1.97	2.40
50 x 40 x 20	2065	40.64	38.60	50.03	1.09
2 x 1 1/2 x 1	300	1.73	1.65	2.02	2.54
50 x 40 x 25	2065	43.94	41.91	51.30	1.15
2 x 1 1/2 x 1 1/4	300	1.90	1.82	2.10	2.85
50 x 40 x 32	2065	48.26	46.22	53.34	1.30
2 x 1 1/2 x 1 1/2	300	1.49	1.41	1.88	2.24
50 x 40 x 40	2065	37.84	35.81	47.75	1.02
2 x 1 1/2 x 2	300	2.25	2.16	2.25	3.75
50 x 40 x 50	2065	57.15	54.86	57.15	1.70
2 x 2 x 1/2	300	1.49	1.49	1.88	2.60
50 x 50 x 15	2065	37.84	37.84	47.75	1.18
2 x 2 x 3/4	300	1.60	1.60	1.97	2.71
50 x 50 x 20	2065	40.64	40.64	50.03	1.23
2 x 2 x 1	300	1.73	1.73	2.02	2.97
50 x 50 x 15	2065	43.94	43.94	51.30	1.35
2 x 2 x 1 1/4	300	1.90	1.90	2.10	3.32
50 x 50 x 32	2065	48.26	48.26	53.34	1.51
2 x 2 x 1 1/2	300	2.02	2.02	2.16	3.72
50 x 50 x 40	2065	51.30	51.30	54.86	1.69

▲ - Working Pressure Ratings are for reference only and based on Sch. 40 pipe. For the

40 x 32 x 32	2065	46.22	44.45	47.75	1.00
--------------	------	-------	-------	-------	------

latest UL/ULC, and FM pressure ratings versus pipe schedule, please visit [anvilintl.com](http://anvilintl.com) or contact your local Anvil Representative.



[www.anvilintl.com](http://www.anvilintl.com)

REV. 4.5.12 - 5